

# **DRINKING WATER NOTICE**

## **Niles City Public Water System**

### **Significant Deficiency/Treatment Technique Requirements**

The Ohio EPA has identified, through the sanitary survey site visit on September 29, 2020, a significant deficiency associated with the public water system (PWS). The Niles City PWS did not comply with Backflow Prevention and Cross Connection Control requirements (Ohio Administrative Code Chapter 3745-95) by February 17, 2021. The Niles City PWS has not completed all required backflow prevention surveys and investigations of service connections and has not ensured that all required containment backflow preventers have been installed, inspected, and tested as required.

#### **What should I do?**

- **There is nothing for you to do at this time.**

#### **What does this mean?**

- This situation does not require that you take immediate action. If it had been, you would have been notified immediately.

#### **What happened? What is being done?**

- We are investigating and taking the necessary steps to correct the problem as soon as possible.

For more information, please contact Kevin Robertson at 330-544-9000 X1171 and/or  
name of contact phone number  
34 West State St, Niles, OH 44446.  
mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWSID#: OH7802403

Date distributed:

Tier 2: Treatment Technique Violation (Significant Deficiency type 45/FC)